

## Title 19, Division 1, Chapter 5, Article 6

### §906.2 Engineered and Pre-Engineered Fixed System Service Tags

- (a) The tags shall be of the hanging type with the option of a self-adhesive type. Tags shall be placed on the agent supply tank enclosure or manual pull device for pre-engineered and engineered fixed systems.
- (b) The following format shall be used for all tags:

The diagram illustrates the required format for fixed system service tags, showing both the front and back views. The front view is a rectangular tag with a width of 5.250 and a height of 2.625. It features a circular hole on the left side for hanging. The tag is divided into several sections: a top section for 'FIXED SYSTEMS' with 'RESTAURANT' and 'INDUSTRIAL' options; a middle section for 'COMPANY NAME', 'STREET ADDRESS', 'CITY STATE ZIP CODE', and 'PHONE NUMBER'; and a bottom section for a monthly calendar from January to December. The back view shows a similar layout with a circular hole on the left and a section for 'FUSIBLE LINKS' with 'TEMP.' and 'DATE OF MFG.' fields.

**FRONT**

**BACK**

This diagram provides a detailed front view of the fixed system service tag. The tag has a width of 5.250 and a height of 2.625. It includes a circular hole on the left side for hanging. The tag is divided into several sections: a top section for 'FIXED SYSTEMS' with 'RESTAURANT' and 'INDUSTRIAL' options; a middle section for 'COMPANY NAME', 'STREET ADDRESS', 'CITY STATE ZIP CODE', and 'PHONE NUMBER'; and a bottom section for a monthly calendar from January to December. The tag also includes a section for 'FUSIBLE LINKS' with 'TEMP.' and 'DATE OF MFG.' fields.

**FRONT**

NOTE: Authority cited: Section 13195, Health and Safety Code. Reference: Section 13195 Health and Safety Code.